
magnetic field sensor for pneumatic cylinders BIM-UNR-AN6X 7M W/M



| BIM-UNR-AN6X 7M W/M |
|--------------------------------|
| 4685851 |
| ≤ 3 m/s |
| ≥ ± 0.1 mm |
| ≤ 0.1 mm |
| ≤ 1 mm |
| ≥ ± 0.1 mm |
| -25+ 70 °C |
| 10 30 VDC |
| \leq 10 % U _{ss} |
| ≤ 100 mA |
| ≤ 15 mA |
| ≤ 0.1 mA |
| ≤ 0.5 kV |
| yes / cyclic |
| ≤ 1.8 V |
| yes / complete |
| 3-wire, NO contact, NPN |
| ≤ 0.3kHz |
| rectangular, UNR |
| 18 x 2.9 x 4.6 mm |
| Plastic, PP |
| Plastic, PP |
| 0.2 Nm |
| cables |
| Ø 2, grey, Lif9Y-11Y, PUR, 7 m |
| 3 x 0.08mm ² |
| 40 x 0.05mm ² |
| 55 Hz (1 mm) |
| |

Switching state

Mounting on the following profiles

Included in scope of supply

Shock resistance

Protection class

LED yellow cable clip


30g (11 ms) IP67

O Ξ Ξ \Box O



- For C-groove cylinders without mounting accessories
- Optional accessories for mounting on other cylindrical housings.
- One-hand mounting possible
- Stable mounting
- Magneto-resistive sensor
- DC 3-wire, 10...30 VDC
- NO contact, NPN output
- Cable connection

Wiring diagram



Functional principle


Magnetic field sensors are activated by magnetic fields and are especially suited for piston position detection in pneumatic cylinders. Based on the fact that magnetic fields can permeate non-magnetizable metals, it is possible to detect a permanent magnet attached to the piston through the aluminium wall of the cylinder.


magnetic field sensor for pneumatic cylinders BIM-UNR-AN6X 7M W/M



Mounting instructions

mounting instructions





One-hand mounting of the sensor in the groove from the top. The sensor can be mounted as follows with the patented wing screw: The wing screws and the female thread feature a left-hand thread. Two small plastic lips keep the screw in position and guarantee a ready-to-install sensor on delivery. With clockwise rotation, the screw is removed from the thread and hits the upper grooves with the wings. As a consequence, the sensor is pressed down and is thus locked. A quarter turn of . the screw with a standard screw driver or a 1.5 mm Allen key is enough for vibration resistant mounting. The allowed fixing torque of 0.2 Nm is sufficient for safe mounting without damaging the cylinder. Cable clips are included in the scope of delivery to enable smooth cable routing in the groove. Accessories for mounting on other cylindrical housings have to be ordered separately.